


|   |  |
|---|--|
| <br><div style="border: 1px solid black; padding: 2px; width: fit-content; margin: 5px auto;">ವಿಶ್ವಾಸದ ಪ್ರತೀಕ</div> | <h2 style="color: blue;">Karnataka Gramin Bank</h2> <p>(A scheduled Bank established by Govt. Of India:<br/>Sponsored by Canara Bank)</p>  |
|   | <p><b>G A Wing: Head Office.</b><br/> <b>#8/2, 2<sup>nd</sup> Floor, Akshaya Square, Opp. Gandhi Nagar Hospital,</b><br/> <b>Gandhi Nagar, Bellary-583103</b><br/> <b>Phone: 08392-470019/20/21</b><br/> <b>e-mail:psitw.premises@kgbk.com</b></p> |
| <div style="display: flex; justify-content: space-between;"> <span><b>REF:KGB/HO/P&amp;S/COR1/2024-25</b></span> <span><b>Date :05.09.2024</b></span> </div>  |  |

### CORRIGENDIUM TO PRE BID QUERIES DATED 04.09.2024

Committee has decided to amend the following in respect of the above RFP based on the query raised:

| <u>Section /Page/Reference of RFP</u>                               | <u>Queries</u>   | <u>Amendments /reply</u>   |          |         |             |          |       |               |      |       |
|---|--|--|----------|---------|-------------|----------|-------|---------------|------|-------|
| <u>91/01/Price Bid</u>  | Can we provide any other type of BIS certified Panel   | As per RFP only BIS certified panels to be provided.   |          |         |             |          |       |               |      |       |
| <u>91/2/Price Bid</u>   | Can we provide any other type of BIS certified Inverter  | As per RFP only BIS certified inverter to be provided.   |          |         |             |          |       |               |      |       |
| <u>5/3/Eligibility Criteria</u>                                     | Can we provide a letter for customer name, postal address, email ID, Contract details as our work order does not have all this information | Letter under company letterhead signed by the appropriate authority can be submitted.  |          |         |             |          |       |               |      |       |
| <u>5/1/ Eligibility Criteria</u>                                    | Whether we have to provide 1 project /year for each 04 districts   | Company to provide 01 completed project report per year for last 05 years (5 reports).   |          |         |             |          |       |               |      |       |
| <u>80/19/Schedule C Technical specification of SPV power plant.</u> | It is not possible to provide 24300 kWh for 14 KWp system  | Power generation for 14 KWp should be between 18000 kWh to 20000 kWh.  |          |         |             |          |       |               |      |       |
| <u>83/B4/ Technical specification -SPV module</u>                   | Technical specification its mentioned panel should not be lesser than 545 Wp and price bid it is mentioned as 550Wp, please clarify.       | Company to provide 550Wp panels  |          |         |             |          |       |               |      |       |
| Not provided  | D G Rating   | <table><tr><td>Mysuru</td><td>Tumkuru</td><td>Chitradurga</td><td>Kalburgi</td></tr><tr><td>125Kw</td><td>Not Available</td><td>82Kw</td><td>100Kw</td></tr></table> | Mysuru   | Tumkuru | Chitradurga | Kalburgi | 125Kw | Not Available | 82Kw | 100Kw |
| Mysuru  | Tumkuru  | Chitradurga  | Kalburgi |         |             |          |       |               |      |       |
| 125Kw   | Not Available  | 82Kw   | 100Kw    |         |             |          |       |               |      |       |
| <u>91/4/Price Bid</u>   | Cable size will vary on design   | Cable according to design and power to be provided   |          |         |             |          |       |               |      |       |
| <u>91/4/Price Bid</u>   | AJB will vary on design  | Standard AJB according to design and power to be provided  |          |         |             |          |       |               |      |       |
| <u>6/2.9/Check list</u>   | Can we submit test certificate later if we get the project successfully  | Yes company can submit at a later stage, In case of past year installed/commissioned projects.   |          |         |             |          |       |               |      |       |
| <u>38/30.1/ Payment terms</u>                                       | What will be the amount of the Bank Guarantee we might have to provide for 5years?   | 2 to 5 % of the estimated value subject to a maximum of rupees One Crore.  |          |         |             |          |       |               |      |       |

All the other instructions and terms & conditions of the above RFP shall remain unchanged.  
Please take note of the above amendments while submitting your response to the subject RFP.

----Sd---  
GENERAL MANAGER